



TEES		BENDS							
RUN	BRANCH				SIZE OF PIPE	DEGREE OF BEND			
	3", 4", 6"	8"	12"	16"		11¼°	22½°	45°	90°
3", 4", 6"	L D	L D	L D	L D	8"	L D	L D	L D	L D
8"	14"	8"	18"	12"	12"	9"	8"	14"	8"
12"	9"	12"	18"	12"	16"	8"	16"	14"	18"
16"	8"	16"	14"	16"	> 16"	16"	18"	24"	18"
> 16"	TO BE DETERMINED IN FIELD BASED ON GROUND CONDITIONS				> 16"	TO BE DETERMINED IN FIELD BASED ON GROUND CONDITIONS			

COUNTY: MEDINA | TOWNSHIP: MEDINA

DRAWN BY: [REDACTED] | REVIEWED BY: [REDACTED] | DATE: MAY 2010

SCALES: HORIZONTAL N/A / VERTICAL N/A

NO.	DESCRIPTION	DATE

**WATER MAIN STANDARDS**

STA. 0+00 to STA. 0+00

PLAN PREPARED BY:  
**MEDINA COUNTY SANITARY ENGINEER**  
AMY LYON GALVIN, P.E.  
701 WEST SMITH RD.  
MEDINA CITY, OHIO 42366  
(330) 725-9585 - (330) 225-3113

PROJECT NUMBER: 000/00-00.0

SHEET NUMBER: 1 / 1

